



# SIVA INSTRUMENTS

## INSULATION TESTER MODEL - 15K4



## Technical Specifications

Test Voltage :500 V, 1000 V, 2500 V & 5000 V , 10000 V, 15000 V  
Resistance ranges :0-500M & 500M – 500G  
Accuracy & repeatability :±5% as per IS2992  
Test timer range :0 to 99 minutes  
Leakage current measurement :1nA to 2 mA, ±5% accuracy  
Interface port : RS232  
Display : LCD, numerals, text and bar-graph  
Power : Rechargeable Ni-Cd batteries  
Charging modes : (a) From D.C. (b) From 230 V, 50Hz mains  
Operating temperatures : -10 to +40°C  
Altitude : 2000 m  
Enclosure Protection class : IP40

## Special Features

- Polarization index test facility
- Short circuit limit facility
- 0 to 5000 V dc ramp for breakdown testing
- Storage facility for test results

To keep pace with the latest technology Sivananda Electronics reserves the right to update it's system. Hence, information in the brochure is likely to change without notice.

An ISO  
9001:2000  
Company



International Standards  
Certification  
Lk No. QAC200000

## SIVANANDA ELECTRONICS

DEEPAK MAHAL, LAM ROAD, DEVLALI-422401, NASHIK. MAHARASHTRA, INDIA.

Phone : 0253-2491423, 2491504, 2491816 E-mail : mkb@sivanandaelectronics.com Fax: 0253-2492291

MUMBAI :208, MIDAS, Sahar Plaza Complex, Andheri Kurla Road, Andheri (E), MUMBAI-400 059, PHONE:022-56430590 / 91 / 92 FAX: 022-28389232

NEW DELHI : G -145, KALKAJI, NEW DELHI -110 019, PHONE : 26221582, 26434442

BANGALORE : 44/2, DICKENSON ROAD, BANGALORE - 560 042, PHONE : 5585673

HYDERABAD : 310, JAMUNA MANSION, CHIRAG ALI LANE, ABIDS, HYDERABAD-500 001, PHONE : 23202943

MFRS. OF : ELECTRONIC INSTRUMENTS, METAL DETECTORS, TURNSTILES, COMPUTERISED TIME ATTENDANCE RECORDING & ACCESS CONTROL